



ULR -TC420125100000293F

TEST REPORT

Water Sample Analysis

Test Report No : EKOW-001/190625

Issue Date : 23/06/2025

Issued To : SPRING FIELD ACADEMY,
Najibabad - Nangal Road, Nayagaon, Mandawall,
Najibabad, District - Bijnor

Sample Description : Drinking Water
 Sample Drawn on : NA
 Sample Drawn by : Given By Client
 Sample Received on : 19/06/2025
 Sampling Location : NA
 Sampling Plan & Procedure : NA
 Sample Quantity : 1.0 Litre
 Environmental Conditions : NA
 Analysis Duration : 19/06/2025 To 23/06/2025
 Remark (if any) : NA

RESULTS


S. No.	Parameters	Test Methods	Results	Units	Limits as per IS:10500-2012	
					Acceptable	Permissible
1	Colour	IS: 3025 (P-4)-A :2021	BLQ (LOQ-1.0)	Hazen	5	15
2	Odour	IS: 3025 (P-5) : 2018	Agreeable	-	Agreeable	Agreeable
3	Taste	IS: 3025 (P-7) :2017	Agreeable	-	Agreeable	Agreeable
4	Turbidity	IS: 3025 (P-10): 2023	BLQ (LOQ-1.0)	NTU	1	5
5	pH	IS: 3025 (P-11) 2.0: 2022	7.46	-	6.5-8.5	No relaxation
6	Total Hardness (as CaCO ₃)	IS: 3025 (P-21)-A : 2009	180.0	mg/L	200	600
7	Total Alkalinity (as CaCO ₃)	IS: 3025 (P-23): 1986	164.0	mg/L	200	600
8	Chloride (as Cl)	IS: 3025 (P-32)-2.0 : 1988	24.5	mg/L	250	1000
9	Residual Free Chlorine	IS: 3025 (P-26)-C : 2021	BLQ (LOQ-0.1)	mg/L	0.2	1
10	Fluoride (as F)	IS: 3025 (Part - 60) -B : 2008	BLQ (LOQ-0.1)	mg/L	1	1.5
11	Total Dissolved Solids	IS: 3025 (P-16): 2023	238.0	mg/L	500	2000
12	Total Coliform	IS: 15185: 2016	Not Detected	Per 100mL	Should be Not Detectable	

Remark- as per the above tested parameters results only, water sample confirm to IS :10500.2012

Notes:


- The results given above are related to the tested sample, as received & mentioned parameters
The customer asked for the above tests only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the Laboratory.
- The test samples will be disposed off after 15 days from the date of issue of test report, unless until specified by the customer. Sample received for biological tests will be destroyed after 7 days from the date of issue of test report.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- BLQ=Below Limits of Quantification, LOQ= Limits of Quantification

End of Report



[Signature]

Kuldeep Singh (Manager)
SPRING FIELD ACADEMY
 Affiliated to C.B.S.E. Delhi (2131179)
 Najibabad - Nangal Road, Mandawali
 Najibabad, Dist. Bijnor (U.P.) 246749



[Signature]

Dr. Karuna Sharma (Principal)
SPRING FIELD ACADEMY
 Affiliated to C.B.S.E. Delhi (2131179)
NAJIBABAD - Nangal Road, Mandawali
Najibabad, Distt. Bijnor (U.P.) 246749